

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20243851
Address: 2139 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Kyle Beard	Not Ready	Monday, November 04, 2024

Corrective Action Required:

2	Miscellaneous Correction	- All horizontal joints are to be in middle 24" of portal leg - Horizontal joints can not be at the header to portal leg
---	--------------------------	---

Not ready for inspection
This is a Garage PFH sheeting inspection only

Comments: