

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20231105
Address: 800 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Robb Popp	Partial	Monday, November 04, 2024

Corrective Action Required:

1	Misc	Pre final for units only
		***Building A THROUGHOUT: -Install accessible signage at elevator and stairwells -Seal all floor and ceiling penetrations at mechanical rooms
		4th floor- Units approved
		3rd floor: Units approved
		2nd floor: Units approved
		1st floor: *Seal penetrations at all garage ceilings S3-missing sprinkler escutcheon G5- CO sensor not working

G7-CO sensor not working
1107-painted sprinkler head at bedroom
1110-Painted sprinkler heads throughout
1112- not ready

***Building B:

4th floor:

-Install spark rings at all microwave receptacles

Comments: