

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #:PRSUBD20210481, Public Infrastructure Address: 2550 SW 3RD ST, LEES SUMMIT, MO 64081141 NW MORTON DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

PW Bond Inspection Matt Munger Partial Monday, November 04, 2024

Corrective Action Required

1 Misc Bond Inspection - manholes 28-455 and 28-456 sit a little high in

the road and will need the to be addressed before the bond

expires.

Comments: