

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20243878
Address: 1543 SW ARBOR VALLEY DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Tuesday, November 05, 2024

Corrective Action Required:

1 Misc

- missing stud at LIB wall in garage. (Stud spacing greater than 16" OC)
- provide proper support and slop for all dwv throughout main floor
- rear primary bedroom and great room not frames to cspf specifications.(header stops before wall corner)
- strap top plate where lapped less than 24" W foyer wall
- strap top plate where lapped less than 24" bed 3

Comments: