

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242945
Address: 3718 SW KNOXVILLE CT, LEES SUMMIT, MO 640823716 SW KNOXVILLE CT, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Kyle Beard	Not Ready	Tuesday, November 05, 2024

Informational:

1	Miscellaneous Correction	Exterior of garage sheeting (PHF) passed and is okay to cover
		This is a partial pass only

Corrective Action Required:

2	Miscellaneous Correction	Fire blocking in not completed throughout
---	--------------------------	---

This is not a complete list

Walk your property before scheduling inspections. Not ready

Comments: