

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240102
Address: 377 NW PATCH CT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------|----------|----------------------------|
| Occupancy Inspection - Codes Residential | Robb Popp | Failed | Tuesday, November 05, 2024 |

Corrective Action Required:

| | | |
|---|------|---|
| 1 | Misc | -Complete final grade and sod, splash blocks, sump extension -*Exterior not inspected due to conditions -Adjust garage entry door to self close and latch -Provide lockouts for hardwired appliances -Install anti siphon device on hose bib in basement mech. room -Missing deck railing -Missing deck landing -Hanging fixture above bathtub must comply with E4003.11 and must be rated for damp location |
|---|------|---|

Comments: