

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242574
Address: 366 NW PATCH CT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Robb Popp	Failed	Tuesday, November 05, 2024

Corrective Action Required:

1	Misc	-Support all DWV in attic space max 4' oc- also maintain proper slope to drain -6x6 deck posts to be full height or spliced per detail on S3.0 -Land electrical near furnace and panel -Install bonding screw and jumper at metallic box *OK to insulate do not cover inspection items
---	------	--

Comments: