

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20236029
Address: 827 NE ALGONQUIN ST, LEES SUMMIT, MO 64064829 NE ALGONQUIN ST, LEES SUMMIT, MO
64064825 NE ALGONQUIN ST, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Tuesday, November 05, 2024

Corrective Action Required:

1	Misc	829: -Obtain lawn irrigation permit and submit backflow valve test report to city -Sidewalk and driveway not approved on record -Splash block at downspout -Dryer duct length exceed code. Max allowed length is 20 ft with current number of elbows. -Fb floor opening below bathroom tub -Provide water pressure regulator
---	------	------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

****Only 829 inspected**

Comments: