

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20243667  
Address: 2610 SW TRACKER LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Tuesday, October 29, 2024

Corrective Action Required:

1 Misc

- plans call for 2x6 framing in entry walls
- anchor bolts to be in the middle 1/3 of sill plate(remove insulation for inspection)
- foundation wall studs to meet the requirements of code section R602.9 (not addressed)

**Comments:**