

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20243667  
Address: 2610 SW TRACKER LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                               | Inspector:       | Outcome:  | Date:                      |
|---|------------------|-----------|----------------------------|
| <b>All Rough Inspection - Residential</b> | Mitchell Schwarz | Not Ready | Tuesday, November 05, 2024 |

Corrective Action Required:

|   |      |  |
|---|------|--|
| 1 | Misc | -plans call for 2x6 framing in entry walls<br>-foundation wall studs to meet the requirements of code section R602.9 (not addressed) |
|---|------|--|

**Comments:**