

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242566
Address: 3117 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Wednesday, November 06, 2024

Corrective Action Required:

1	Misc	EROSION CONTROL NOT IN COMPLIANCE INSPECTION DENIED
		NO FURTHER INSPECTIONS UNTIL EROSION CONTROL IS IN COMPLIANCE
		-missing stud at small wall between garage doors -missing plate under header at cspf rear wall both corners(installed incorrectly, plate to be above jack studs) -front entry wall top plate not tied together with adjoining exterior walls -security blocking for front door -missing truss lateral bracing multiple trusses throughout

Comments: