

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE
PROSECUTED**

Permit #: PRRES20240647
Address: 3710 SW CLAYTON PL, LEES SUMMIT, MO 640823712 SW CLAYTON PL, LEES SUMMIT, MO 640823716 SW CLAYTON PL, LEES SUMMIT, MO 640823718 SW CLAYTON PL, LEES SUMMIT, MO 64082

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Dustin Agcopra	Failed - Stop Work	Wednesday, November 06, 2024

Informational

1	Miscellaneous Correction	Full erosion control measures are in place and must be maintained until CofO
---	--------------------------	--

Corrective Action Required

2	DCM3 ESC REQUIRED 2 DAY	11-4-24 Dustin A, all sws have silt due to improper erosion control..EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS.
---	-------------------------	---

11-6-24 Dustin A, nothing has changed

Comments: