

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20243136
Address: 1408 NE ERNEST WAY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Khanh Nguyen	Failed	Wednesday, November 06, 2024

Corrective Action Required:

1	Misc	Install erosion control wattle along the street and clean street. The wattle shall be staked down to the soil, not laying on the street curb
---	------	--

****No further inspection if erosion control is not in compliance.**

Comments: