

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20243136
Address: 1408 NE ERNEST WAY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sewer Service Inspection - R	Khanh Nguyen	Partial	Wednesday, November 06, 2024

Corrective Action Required:

1	Misc	Partial approved about 10 ft of sewer from sewer stub connection toward the house. The rest of the sewer to the house will have to be redone due to elevation of the sewer stub being higher than sewer coming out of the house
---	------	---

Comments: