

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242381  
Address: 2213 NW KILLARNEY LN, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	Robb Popp	Failed	Wednesday, November 06, 2024

Corrective Action Required:

1	DCM2 ESC DEFICIENT INSTALLATION	Clean debris from street, remove loose trash from site
---	---------------------------------------	--

**Comments:**