

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244953
Address: 1909 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Kyle Beard	Failed	Wednesday, November 06, 2024

Corrective Action Required:

1	Miscellaneous Correction	Garage portal PFH inspection only - Exterior sheeting does not extend to the double top plate - Anchor bolts are not located in the middle 1/3 of bottom plate
---	-----------------------------	--

This is a partial inspection only

Comments: