

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20243543
Address: 3208 SW ARBORIDGE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Wednesday, November 06, 2024

Corrective Action Required:

1 Misc

ADDRESS ALL LOW VOLTAGE PENETRATIONS MADE AFTER FIRST INSPECTION

- fire block hvac chase into ceiling space (seal gaps)
- missing hold downs on trusses (check throughout)
- address stud spacing at stairwell wall
- complete electrical in bed 3 and fireblock
- missing lateral bracing throughout
- nail double trusses to plans throughout
- ensure access for clean out under stairs

Comments: