

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20234858
Address: 2147 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Robb Popp	Failed	Thursday, November 07, 2024

Corrective Action Required:

1	Misc	-Connect whip to AC unit-not done on lower unit -Provide AFCI protection at fridge and washer-breakers 1,4 -Anchor column base in mechanical room-not done. (This is column in unfinished wall in room behind stairs)
---	------	---

Comments: