

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20243996  
Address: 3212 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Thursday, November 07, 2024

Corrective Action Required:

1 Misc

- address bath vents for hanging from electrical throughout
- provide solid blocking for floor joist running parallel to foundation and walls(see N side)
- connect ufer ground directly to first point of disconnect
- no gas line installed

**Comments:**