

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20243996
Address: 3212 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Mitchell Schwarz	Not Ready	Thursday, November 07, 2024

Corrective Action Required:

1	Misc	Ufer ground to connect directly to the first means of disconnect.
		Not done not ready-11/07/24

Comments: