



**SAB CONSTRUCTION, LLC.**

**DATE: 10/29/2024**

**PO BOX 942 – LEE SUMMIT, MO 64063**

**ATTN: Plan Review**

**OFFICE – 816.477.3456**

**FAX – 816.524.7260**

**[joe@sabhomes.com](mailto:joe@sabhomes.com)**

### **Transmittal Letter**

Plan review response for Hook Farm, Lot 123. 2614 SW Tracker Ln.

- I am resubmitting engineered plans for permit #PRRES20244071. I had the architectural note on page S-0.3 "NOTE: 2X6 STUDS AT ANY WALL TALLER THAN 12' TALL." Right below the Main Floor Plan Area.
  - This is made by the architect not the engineer. We had to get an engineered letter on HF124 (PRRES20243667) because of this mistake and this time I just had the note removed before inspections, to prevent having to get a letter for the same issue.