

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241801
Address: 2203 SW HOOK FARM DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Thursday, November 07, 2024

Corrective Action Required:

1	Misc	-secure gas line at fireplace -seal top plate penetration in primary closet -Add fireblock at bed 3 closet for vertical to horizontal fireblock ever 10' -add blocking under return air in stud bay stairwell/garage entry wall -ensure siding secured to plans and code
---	------	--

Comments: