

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20240118  
Address: 515 NW MOORE ST, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rough Framing Inspection - Commercial</b>	Robb Popp	Partial	Thursday, November 07, 2024

Corrective Action Required:

1	Misc	**Exterior sheathing for floors 1-4 of units only approved
		*Corridor ceiling framing pre rock inspection: -1st floor ok 2-4th floor- Nail band joists 6" oc, install missing hangers, set nuts at elevator cmu wall

Comments: