

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20243878
Address: 1543 SW ARBOR VALLEY DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Friday, November 08, 2024

Corrective Action Required:

1	Misc	-missing stud at LIB wall in garage. (Stud spacing greater than 16" OC) nail lib in this area to added stud -rear primary bedroom and great room not frames to cspf specifications missing straps at ends
---	------	---

Comments: