

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241487
Address: 3241 SW ARBOR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Ready for Temp CO	Friday, November 08, 2024

Corrective Action Required:

1	Misc	EROSION CONTOL MUST BE MAINTAINED AROUND LOT UNTIL SOD IS IN PLACE
---	------	--

- address pending pier inspection
- pay all fees
- final grade and sod
- will check water meter at time of final grade and sod
- splash blocks and sump pump discharge to extend 36" from foundation

Comments: