

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242856

Address: 1414 SW WINTHROP TER, LEES SUMMIT, MO 64081  
1412 SW WINTHROP TER, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Shawn Hoffman	Failed	Friday, November 08, 2024

Corrective Action Required:

1 Misc

1412

- tighten anchor bolts garage

1214

- top plat not tie in at entry / bedroom 2 (strap)

- Nail 2x6 stud pack together at kitchen refrigerator under double LVL

- Fire block return air space wire penetrations at basement bathroom

**Comments:**