



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20114544, Building Permit - Commercial
Address: 110 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	John Borns	Partial	Friday, October 28, 2011

Partial Correction
1 MISC

OK TO COVER WHEN READY EXTERIOR FACE OF LIGHT-GUAGE
STEEL FRAMING @ THIRD LEVEL FOLLOWING SEGMENTS:
AD'/119 TO EE/12 TO K/3;

Comments: