



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20115173, Building Permit - Commercial
Address: 3340 NE RALPH POWELL RD, Unit:B, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Passed	Friday, October 28, 2011

Comments: OK TO COVER WHEN READY AFTER DUCT INSULATION IS REPAIRED AT LOCATION POINTED OUT AND AFTER ONE ABANDONED SECTION OF LIGHT GAUGE STEEL BRACING IS REMOVED.