

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20241487
Address: 3241 SW ARBOR TREE DR, LEES SUMMIT, MO 64082
Inspected On: Friday, November 08, 2024
Inspected By: Development Center
Expiration Date:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Ready for Temp CO	Friday, November 08, 2024
Corrective Action Required:			
1 Misc	EROSION CONTOL MUST BE MAINTAINED AROUND LOT UNTIL SOD IS IN PLACE		

- address pending pier inspection
- pay all fees
- final grade and sod
- will check water meter at time of final grade and sod
- splash blocks and sump pump discharge to extend 36" from foundation

Comments: