CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20226053

Address: 1021 SE HAMBLEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Storm Sewer Construction Bobby Richest Partial Wednesday, November 06, 2024

Informational:

1 Misc 10-28-24 BR Contractor excavated existing storm box on SE Hamblen Rd. to

lower storm cover. Also contractor excavated for new storm box location

with installing rebar for storm box floor.

10-31-24 BR Contractor poured storm box walls and invert on new storm box.

11-5-24 BR Contractor installed storm box lid on new storm box structure. The existing storm box was cut down to street level and existing 15" RCP pipe

is being excavated.

11-6-24 BR Contractor poured inverts on storm junction box and installed 25'

of 15" RCP pipe coming out of storm box.

11-7-24 BR Contractor installed 25' of 15" RCP pipe to 2nd storm junction box

with box structure installed.

Comments: