

MICHAEL MOORES, RA
(816) 516-4861

Development Services
CITY OF LEE'S SUMMIT, Missouri
220 SE Green Street
Lee's Summit, MO 64063

Re: 1X Plastics
2700 NE McBaine Drive
Lee's Summit, MO 64064
Permit No.: PRCOM20245730

November 8, 2024

Dear Plans Examiner:

We have received your plan review comments and have itemized our responses to correspond with each comment.

Licensed Contractors:

1. The licensed general contractor is NORTH OAK SAFETY STORAGE. The onsite contact is Clayton Ward (816) 786-0028, clayton@safetyministorage.com.

Building Plan Review:

1. Please see the partition type A-1 on Sheet A-110 for the detail of the mechanical platform guard.
2. Please see the revised Sheet E201 which shows the added receptacle at the mechanical platform.

Fire Plan Review:

1. Shop drawings will be submitted for review and approval as a deferred submittal by the Fire Alarm System contractor.
2. Shop drawings will be submitted for review and approval as a deferred submittal by the Fire Suppression System contractor.
3. It is acknowledged that portable fire extinguishers shall be selected, installed and maintained in accordance with IFC 906.2 and NFPA 10.
4. It is acknowledged that portable fire extinguishers shall be located in conspicuous locations in accordance with IFC 906.5 or as determined by the fire code official.

Please call if you have any questions.

Sincerely,

MICHAEL MOORES, RA