



**1 ELECTRICAL POWER PLAN**  
SCALE: 1/4" = 1'-0"

**GENERAL NOTES**  
(NOT ALL NOTES APPLY)

1. REFERENCE SHEET E101 FOR GENERAL NOTES, SYMBOLS, AND ABBREVIATIONS.
2. COORDINATE MOUNTING HEIGHTS AND LOCATIONS FOR ALL DEVICES WITH ARCHITECT AND/OR INTERIOR ELEVATIONS PRIOR TO ROUGH-IN.
3. PROVIDE AND INSTALL 3/4" CONDUIT AND PULL STRINGS FROM TELEPHONE/DATA OUTLETS TO ABOVE ACCESSIBLE CEILING. VERIFY EXACT REQUIREMENTS WITH TELEPHONE EQUIPMENT SUPPLIER AND/OR TENANT.
4. CIRCUIT NUMBERS SHOWN ARE FOR REFERENCE ONLY. CONTRACTOR TO FIELD VERIFY EXISTING CONDITIONS.
5. REMOVE EXCESS WIRING RESULTING FROM DEMOLITION. ELECTRICAL CONTRACTOR TO RE-CIRCUIT OUTLETS LEFT ON INCOMPLETE CIRCUITS.
6. WHERE POSSIBLE, RE-USE SPARE CIRCUITS RESULTING FROM DEMOLITION PRIOR TO PULLING NEW CIRCUITS FROM PANELBOARD.
7. ALL DEVICES AND FIXTURES LABELED 'EX' ARE EXISTING TO REMAIN. ALL DEVICES AND FIXTURES LABELED 'EXR' ARE EXISTING TO BE RELOCATED.
8. EXISTING CONDITIONS INDICATED IN THESE DOCUMENTS ARE BASED ON A CURSORY SITE REVIEW AND DO NOT REPRESENT A COMPLETE "AS-BUILT" SET OF DOCUMENTS. IT IS THE CONTRACTOR'S RESPONSIBILITY TO FULLY INVESTIGATE ALL EXISTING CONDITIONS AND NOTIFY THE ARCHITECT/ENGINEER OF ANY DISCREPANCIES TO THESE DOCUMENTS OR THE DESIGN INTENT.

**KEYED NOTES:**

1. FIELD VERIFY EXACT CONNECTION REQUIREMENTS OF ALL BREAKROOM APPLIANCES WITH OWNER/EQUIPMENT SUPPLIER PRIOR TO ROUGH-IN.
2. CONTROL INTENT IS FOR FAN TO ENERGIZE 'ON/OFF' WITH LIGHTS IN RESTROOM. PROVIDE A RIB RELAY AND ANY ADDITIONAL WIRING OR ACCESSORIES REQUIRED TO INTERLOCK FAN WITH LIGHTING SWITCHES.
3. RECEPTACLE TO BE MOUNTED ON EQUIPMENT PLATFORM IN AN ACCESSIBLE LOCATION. FIELD VERIFY EXACT LOCATION PRIOR TO ROUGH-IN.

Architect:  
MICHAEL MOORES, RA  
t: (816) 516-4861

---

Client:  
Ward Development  
1120 NW Eagle Ridge Blvd.  
Grain Valley, Missouri 64029  
t: (816) 229-8115

---

Consultants:  
MEP Engineering:

**EBS**  
ENGINEERED BUILDING SOLUTIONS, LLC  
1100 N. W. 11th St., Suite 1100  
Overland Park, KS 66207  
913.738.9824  
MO Certificate of Authority PE 0221720222

---

Revisions to technical submissions which are not made or approved by the licensee are prohibited.

Seal:  
  
 11/08/2024  
 MICHAEL MOORES, MO Architect #2009032812

---

Project Number: 2410  
Project Type: TENANT FINISH  
Project Name and Address:

**1X PLASTICS**  
2700 NE McBaine Drive  
Lee's Summit, Missouri 64064

---

Issue:	Date:
Permit Submittal	10.25.24
City Comment Response	11.08.24

---

Sheet Title:  
**ELECTRICAL POWER PLAN**

**E201**