

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20243548  
Address: 1233 NE GOSHEN DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Khanh Nguyen	Failed	Tuesday, November 12, 2024

Corrective Action Required:

1	Misc	-Fb duct chase from joist space **The electrical wiring must be protected. Use insulation to fire block
		-The (3)2x10 beam at stair is notched. Have engineer address this **There's no footing under the wall. Your engineer must address this

**Comments:**