

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242647
Address: 3224 SW ARBORIDGE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Dustin Agcopra	Passed	Tuesday, November 12, 2024

Informational:
1 Misc 11-1-24 Dustin A, SW in front and side of house is compacted and formed.
Slopes are in compliance. Approved to pour
11-12-24 Dustin A, SW is poured and slopes are in compliance Expansion
joint missed on 3 spots, Approved by RH. Pass

Comments: