CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244632

Address: 2778 SW 12TH ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

All Rough Inspection - Shawn Hoffman Failed Tuesday, November

Residential 12, 2024

Corrective Action Required:

2 Misc PORTAL FRAME

- Dining room CS PF nail pattern and straps not done
- Nail pattern at garage CS-PF not done
- Porch OK
- Deck roof is covered could not inspect

Comments: