

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20216450  
Address: 1400 SE RANSON RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Pavement-Surface</b>	Bobby Richest	Partial	Tuesday, November 12, 2024

Informational:  
1 Misc 11-12-24 BR Contractor installed 5" of KCM MB A-3 asphalt base on SE Silo St., SE Windbreak Dr., SE Cronin St. with 3rd party inspector (Ideker Inc.) getting 94 - 96 compaction.

**Comments:**