

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20221553
Address: 1616 SW 27TH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Dustin Agcopra	Passed	Wednesday, November 13, 2024

Informational:
1 Misc 11-6-24 Dustin A, Dw is formed and compacted. Approach was to wide when arrived (40 ft). Contractor took off wings it is now at 36 ft. Approved to pour.

10-13-24 Dustin A, DW is poured to city specs. Passed

Comments: