

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242723
Address: 1054 SW FIORD DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Not Ready	Wednesday, November 13, 2024

Corrective Action Required:

1	Misc	- Ok to cover deck roof - Portal frame nail pattern and sheeting out side ok to cover. straps not installed.
---	------	---

Corrective Action Required:

2	Misc	INSPECTION DENIDE, NNOT READY NO FIRE BLOCKING OR DRAFT STOPPING
---	------	---

Comments: