## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRCOM20231975

Address: 1550 SE HAMBLEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Pavement-Surface Bobby Richest Partial Wednesday,

November 13, 2024

Informational:

1 Misc 11-4-24 BR Contractor (Wil-Pav) poured 5" of asphalt base type 1 asphalt on

east side parking lot.

11-7-24 BR Contractor (Wil-Pav) poured 5" of asphalt base type 1 on south

side and west side of parking lot.

11-12-24 BR Contractor (Wil-Pav) poured 2" of asphalt surface type 3 on

entire parking lot. Ready for striping.

11-14-24 BR Contractor (Wil-Pav) poured 2" of asphalt surface type 3 on

entrance parking lot lane to existing building.

## Comments: