

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242357  
Address: 3212 SW ARBORIDGE CIR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Kyle Beard	Ready for Temp CO	Thursday, November 14, 2024

Corrective Action Required:

2	Miscellaneous Correction	-Sod, splash pads and sump pump extension is not installed -As graded plot plan is required before sodding -seal all exterior penetrations -install missing joist hanger under deck -Install missing nails in joist hanger under deck -Install post to beam fasteners for deck
---	--------------------------	---

Passed for TCO only

Comments: