

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242357
Address: 3212 SW ARBORIDGE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Failed	Thursday, November 14, 2024

Corrective Action Required:

2	Miscellaneous Correction	-Sod, splash pads and sump pump extension is not installed -As graded plot plan is required before sodding -seal all exterior penetrations -install missing joist hanger under deck -Install missing nails in joist hanger under deck -Install post to beam fasteners for deck
---	--------------------------	---

Passed for TCO only

Comments: