

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20244457  
Address: 1020 NW PRYOR RD, Unit:A, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Robb Popp	Failed	Friday, November 15, 2024

Informational:	
1 Misc	-Hard lids approved
Corrective Action Required:	
2 Misc	-Seal penetrations in firewall above cooler *ok for tile in other areas-do not cover inspection items

**Comments:**