

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241067
Address: 2087 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Robb Popp	Not Ready	Friday, November 15, 2024

Corrective Action Required:

1	Misc	10/23/24 Note from Gas service inspection: -CSST secured in joist space less than 3" to bottom of joists requires 16g striker plate-EVERYWHERE CSST IS SECURED LESS THAN 3" TO BOTTOM OF JOIST PROTECTION IS REQUIRED
---	------	--

Corrective Action Required:

2	Miscellaneous Correction	11/15/24 *No address. Not ready. No inspection performed -Pay all fees due before occupancy
---	-----------------------------	---

Comments: