

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242945

Address: 3718 SW KNOXVILLE CT, LEES SUMMIT, MO 640823716 SW KNOXVILLE CT, LEES SUMMIT, MO
64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Kyle Beard	Failed	Friday, November 15, 2024

Corrective Action Required:

1	Miscellaneous Correction	Fire rated roof sheathing at ridge in unit 3716 has a gap larger than 1/4 of an inch (Provide information on caulking used)
		3718 Better seal electrical service cable and bonding wire at demising wall

Comments: