

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20243123

Address: 3717 SW KNOXVILLE CT, LEES SUMMIT, MO 64082
3719 SW KNOXVILLE CT, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Kyle Beard	Failed	Friday, November 15, 2024

Corrective Action Required:

1	Miscellaneous Correction	3717 and 3719 SW Knoxville. Rated assembly
		3717 Fire rated roof sheathing along the west side has a greater than 1/4 of an inch gap Fire rated demising wall does not extend to the roof sheathing along ridge at west side above bedroom 1 (fire rated sheathing was installed)
		3719 Fire rated roof sheathing at the ridge has a greater than 1/4 of an inch gap

Comments: