

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242155
Address: 1632 SW BUCKTHORN ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Failed	Monday, November 18, 2024

Corrective Action Required:

1	Miscellaneous Correction	<ul style="list-style-type: none">-Overhead garage doors are not completed-Exterior electrical receptacles need to be for wet locations Self-Deck to beam fasteners are not installed-Driveway final is not complete-Sidewalk final is not complete-Sod, splash pads and sump pump extension need to be completed-Seal all exterior penetrations-Pay \$525 in fees associated with this permit
---	--------------------------	---

Comments: