

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20243123

Address: 3717 SW KNOXVILLE CT, LEES SUMMIT, MO 64082
3719 SW KNOXVILLE CT, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--------------------------------------|------------|----------|---------------------------|
| Electrical Service Inspection | Kyle Beard | Failed | Monday, November 18, 2024 |

Corrective Action Required:

| | | |
|---|--------------------------|---------------------------------------------|
| 1 | Miscellaneous Correction | Both units |
| | | - Electrical lines are not landed in panel |
| | | - Secure all electrical above panel to code |

Comments: