



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

Prevention Division
(816)969-1300

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20235113	Date:	November 18, 2024
Project Title:	LXT - LEE'S SUMMIT AIRPORT EASTSIDE DEVELOPMENT - HANGAR 2	Applicant:	
Location:	2740 NE HAGAN RD, Unit:A, LEES SUMMIT, MO 640642740 NE HAGAN RD, Unit:B, LEES SUMMIT, MO 640642740 NE HAGAN RD, LEES SUMMIT, MO 64064	ENVISION TECHNOLOGY GROUP 6985 W 153RD ST OVERLAND PARK, KS 66223	
Type of Work:		Primary:	(913) 491-1700
Occupancy Group:	S-1		
Description:	LEE'S SUMMIT AIRPORT (LXT) NEW HANGAR WITH OFFICES AND EDUCATIONAL SPACES - ASSOCIATED SITE DEVELOPMENT COVERED BY CIP (CAPITAL IMPROVEMENT PROJECT)		

Mike Weisenborn 04/10/2024 12:19 PM - PARTIAL PERMIT ISSUED. WORK RELEASED IS FOOTINGS, PIERS, UNDERSLAB AND SLAB
Construction Type: Type IIB (Unprotected)
Map Page:

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Craig Hill

Released for Construction

1. 2018 IFC 904.4.2- Alarm testing. Notification appliances, connections to fire alarm systems, and connections to approved supervising stations shall be tested in accordance with this section and Section 907 to verify proper operation.

Information Only: Call (816) 696-1300 for testing

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.