

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20231351  
Address: 2840 SE BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Water Line - Coliform Test 2</b>	Bobby Richest	Partial	Thursday, November 07, 2024

Informational:

1	Misc	11-7-24 BR Contractor 2nd sample on water line A, line G, line B, & line C coliform test.
		11-12-24 BR 2nd sample came back with 2 out of 3 samples has pass. 1 sample spot needs the taking again do to not passing.

**Comments:**