

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242155
Address: 1632 SW BUCKTHORN ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Dustin Agcopra	Partial	Tuesday, November 19, 2024

Corrective Action Required:

1	Misc	11-15-24 Dustin A, Sw is poured and slopes are in compliance. Expansion joints were not used attaching to existing SW's. Failed
		11-19-24 Dustin A, SW has been cut back out. Approved to pour with expansion joints

Comments: